



SPECIFICATION : -

- a) End Flange and Centre Sleeve : Rolled Steel To BS EN 10025 S275 (BS 4360 Grade 43A) or equivalent
- b) Finishing : Fusion Bonded Epoxy Powder Coated  
Approx 200 microns thk
- c) Bolts, nuts & washers : Carbon Steel to BS970 Part 1 Grade 070 M20  
Galvanised to BS 3382 then FBEP coated
- d) Sealing ring : NR To BS EN 681-1 : 1996  
Type 'WA'

DN	OD	TOL ON OD FOR LGTH L	L	A	B	SLEEVE C x AV THK	BOLTS		QTY
							NO	DIA x LGTH	
500	508	±1.6	150	605	239	150 x 8	10	M12 x 230	2



**PIPEMATE SDN BHD**  
MALAYSIA  
TEL : 603 - 61380977  
FAX : 603 - 61388772

CLIENT : JTM

PROJECT : TAURANGA PUMPING STATION

TITLE : 'PM' COUPLING

DR BY : Y. C. SEE

CK BY : K. H. LEE

SCALE : NTS

DRG NO : PM/MC/3948/05

REV :

DATE : 08/06/05