



SPECIFICATION : -

- a) End Flange and Centre Sleeve : Rolled Steel To BS EN 10025 S275 (BS 4360 Grade 43A) or equivalent
- b) Finishing : Fusion Bonded Epoxy Powder Coated
Approx 350 microns thk
- c) Bolts & nuts : HDG Steel to ISO 898-1 Gr 8.8 & DIN 267-4 Gr 8
- d) Sealing ring : NBR To BS EN 681-1 : 1996
Type 'WA'
- e) Working Pressure : 10 bars

Item No	DN	OD	TOL ON OD FOR LGTH L	L	A	B	SLEEVE C x AV THK	BOLTS		QTY
								NO	DIA x LGTH	
10/11/20/26	500	508	±2.0	150	604	339	250 x 8	10	M12 x 330	8
-	350	355	±2.0	150	451	339	250 x 8	8	M12 x 330	4



PIPEMATE SDN BHD

email : pipemate@tm.net.my
TEL : 603 - 61380977
FAX : 603 - 61388772

CLIENT : Eastern Tertiary Alliance

PROJECT : MWC Eastern Treatment Plant (ETP)

TITLE : 'PM' COUPLING

DRAWN BY : Theresa

CHECKED BY : KH LEE

APPROVED BY : KH LEE

DRG NO : PM/MC/6509/10

REV : 1

DATE : 23/9/2010

SCALE : NTS